



Introduction

The Challenge

Climate Crisis: IPCC identifies Direct Air Capture (DAC) as essential technology for achieving 1.5°C warming limits
Gigatons Required: Must scale to billions of tons CO₂ removal annually by 2050

Hard-to-Abate Sectors: DAC needed to balance residual emissions from aviation, shipping, cement production

Market Opportunity

Policy Support: U.S. Section 45Q tax credits (\$50-85/ton CO₂)

Growing Investment: Government and private funding accelerating globally

Commercial Demand: Carbon removal markets expanding rapidly

Our Approach

Proven Chemistry: Potassium carbonate sorbent system (Keith et al., 2018)

Process Innovation: Integrated thermal management with heat recovery

Modular Design: Scalable for diverse deployment scenarios



Pellet Reactor

Function & Chemistry

Oxy-Fired Circulating Fluidized Bed Reactor

Key Reaction: $K_2CO_3(aq) + CaOH_2(s) \rightarrow KOH(aq) + CaCO_3(s)$

Purpose: Crystallize >0.9 mm CaCO₃ solid pellets via causticization reaction

Design Specifications

Operating Conditions: 21°C, 1 bar (ambient)


Volume: 195.2 m³ (D = 3.96 m, H = 15.85, A = 12.33 m², H/D = 4)

Upward Fluidization Velocity: 1.65 cm/s

Material: Carbon Steel (t=2.62 mm)

with FRP liner (t = 4 mm)

Calcium Retention Rate: 90%, 10% exit as fines



Contactor

Function

& Chemistry

CO₂ Absorption: Ambient air (400 ppm CO₂) → Aqueous KOH sorbent

Key Reaction: $CO_2(g) + 2KOH(aq) \rightarrow K_2CO_3(aq) + H_2O(l)$

Target Performance: 74.5% CO₂ capture efficiency

Design Specifications

Reactor Type: Spray tower (current) / Packed bed (optimized)

Volume: 26.3 m³ (D = 2.15 m, H = 5.38 m, H/D = 2.5)

Operating Conditions: 21°C, 1 bar

Material: Carbon steel + FRP coating (caustic resistance)

Optimization Achievement


Packed Bed Upgrade:

PP Raschig Rings: 150 → 225 m²/m³ surface area

Efficiency Gain: 74.5% → 89.2% (+457 kmol/h CO₂)

Economic Benefit: \$39,770 capital savings + \$5,500/year operational savings

Trade-off: 810 Pa pressure drop requiring 57.1 kW additional fan power



Calciner

Function & Chemistry

Regeneration: Thermal decomposition of potassium bicarbonate back to carbonate

Key Reaction: $CaCO_3(s) \rightarrow CO_2(g) + CaO(s)$

Target Performance: 98% conversion

Design Specifications

Reactor Type: Fluidized-bed calciner for uniform heating and high throughput

Volume: 84 m³ (D = 3.3 m, H = 9.8 m, H/D = 3)

Operating Conditions: 900°C, 1 bar

Material: Inconel 601 (hot zone liner) + SA-516 Gr70 Carbon Steel

Slaker

Function & Chemistry

Regeneration: Hydration of calcium oxide (quicklime) to calcium hydroxide (slaked lime)

Key Reaction: $CaO(s) + H_2O(l) \rightarrow Ca(OH)_2(s)$

Target Performance: 98% conversion


Design Specifications

Reactor Type: Fluidized-bed calciner for uniform heating and high throughput

Volume: 30 m³ (D = 2.3 m, H = 7.0 m, H/D = 3)

Operating Conditions: 300°C, 1 bar

Material: 304 Stainless Steel (wetted surface) + SA-516 Gr70 Carbon Steel



Results

Overall Performance

CO₂ Capture: 1.29 Mt/year

Product Quality: 100% CO₂ purity at 151 bar, 40°C

Energy Integration Success

Heat Generated: 527.7 MW total recoverable heat

Heat Required: 175.5 MW (calciner only)

Net Surplus: 352 MW available for cogeneration

Utility Savings: \$28.94 M/year through pinch analysis

Optimization Results

Packed bed upgrade for Contactor: +14.7% efficiency (+457 kmol/h CO₂)

Economic gain: \$39,770 capital + \$5,500/year operational savings

Environmental Impact

Gross Emissions: 79.1 t CO₂/ hr (methane + electricity)

CO₂ Captured: 147.3 t CO₂/hr

Net Removal: +68.2 t CO₂/hr (29,700 t/year)

Material Balance

Calcium Loop: 0.029% imbalance at the pellet (excellent closure)

Potassium Loop: Stable convergence achieved

Economics

Unoptimized Economics

Total Grass Roots Cost: M\$289

Land Cost: M\$30

Working Capital: M\$43.35

Revenue

Government Credits: M\$30

CO₂ as a Commodity: M\$30

Carbon Credits: \$8

Total: M\$68

Operating Expenses

Utility Cost: M\$198,422

Labor Cost: M\$1.15

Waste Treatment: M\$0

Raw Materials: M\$0

Cost of Manufacturing: M\$244,145

NPV: - \$2.02 trillion

Optimized Economics

Total Grass Roots Cost: M\$455.7

Land Cost: M\$30

Working Capital: M\$68.36

Revenue

Government Credits: M\$30

CO₂ as a Commodity: M\$30

Carbon Credits: \$8

Total: M\$68

Operating Expenses

Utility Cost: M\$90,114

Labor Cost: M\$1.15

Waste Treatment: M\$0

Raw Materials: M\$15.088

Cost of Manufacturing: M\$129.485

NPV: - \$1.07 trillion

Conclusions & Recommendations


Conclusions:

- Current DAC system surpassed technical targets with 1.29 Mt-CO₂/year captured
- Improvements are still necessary to achieve economic feasibility

Recommendations:

- Electrical and thermal utility demands must be decreased as they are the major drivers of operational costs
- Modular construction strategies and closer engagement with equipment vendors are advised

Storage



Acknowledgements

Plant design based on Carbon Engineering's DAC plant in Squamish, BC

Dr. Drews, Dr. Russ, Dr. Powell

UCSD Jacobs School of Engineering,
Department of Chemical and Nano
Engineering

Environmental

Net Carbon Balance

- Gross CO₂ emissions: 79 114 kg/hr (59 114 kg/hr from CH₄ combustion + 20 000 kg/hr from grid electricity)
- CO₂ captured: 82 500 kg/hr
- Net removal: +3 386 kg CO₂/hr → ~29 700 t CO₂/yr

Water Management

- Zero external discharges: no wastewater or solid waste leaves the site
- Water recycle: crystallizer blowdown via ZLD evaporator recovers ≥ 95 % of process water

Emissions

- Near-zero fugitive particulates due to sealed reactors and baghouse filters
- No NPDES permit needed: all blowdown is neutralized and routed to municipal sewer under existing industrial permit

Optimization (Heat Recovery)

Table 6: Annual Utility Costs: Baseline vs. Pinch-Integrated				
Utility (\$/kW-hr) ^a	Duty (MW)	Unit Cost Annual Cost (\$ × 10 ⁶)	Duty (MW)	Unit Cost Annual Cost (\$ × 10 ⁶)
Baseline (No Integration)				
Cooling Water (CW)	159.75	8.00	159.75 × 8 = 1,278.0	\$10.22
Fired Heater (Natural Gas)	95.19	30.00	95.19 × 8 = 761.5	\$22.85
Total Baseline Cost			2,039.5	\$33.07

Pinch-Integrated (Optimization #1)				
Cooling Water (CW)	64.55	8.00	64.55 × 8 = 516.4	\$4.13
Fired Heater (Natural Gas)	6.00	30.00	6.00 × 8 = 48.0	\$0.49
Total Pinch Cost			516.4	\$4.13

Annual Savings: Baseline – Pinch				
Cooling Water (CW)	95.20	-	95.20 × 8 = 761.6	\$6.09
Fired Heater (Natural Gas)	95.19	-	95.19 × 8 = 761.5	\$22.85
Total Savings	190.39	-	1,523.1	\$28.94

